

MASSACHUSETTS DEP/DIVISION OF WATER SUPPLY
INORGANICS REPORT (FORM #1A.3)

RECEIVED SEP 07 2006

inr

I. PWS INFORMATION:

1. PWS ID#: 1191000 2. City/Town: MONSON
 3. PWS Name: Monson Water & Sewer Dept. 4. PWS Class (circle one): COM, NTNC, NC
 5. DEP Source Code/Location ID Bunyan Rd. 6. Sample Location Wells 7. Date Collected 8/7/06 8. Collected by C. Jalbert
 9. Is the Source Treated? Y 10. Was the Sample Collected after Treatment? Y
 11. Manifolder: [] If applicable, list the connected sources:

12. Routine [X] Special [] (explain below)

Notes:

II. LABORATORY ANALYTICAL INFORMATION:

Lab Name: Spectrum Analytical, Inc. Lab Cert.#: MA138/MA1110
 Subcontracted? (Y,N) N Lab Sample ID#: sa49098-01
 (use symbols to relate each analyte to a specific lab)
 Sub. Lab Name: _____ Cert. #: _____ Lab Symbol: _____
 Composite: [] If applicable, list the composited sources (DEP Source Code/Sample Location):

Notes:

Compound (regulated)	Lab Sample ID#	Result mg/L	MCL mg/L	Detection Limit mg/L	Analytical Method	Date Analyzed	Lab Symbol
Arsenic	SA49098-01	BRL	0.05	0.0005	EPA 200.8	8/8/06	---
Barium	SA49098-01	0.0307	2.0	0.0005	EPA 200.8	8/8/06	---
Cadmium	SA49098-01	BRL	0.005	0.0005	EPA 200.8	8/8/06	---
Chromium	SA49098-01	0.0017	0.1	0.0010	EPA 200.8	8/8/06	---
Fluoride*	SA49098-01	BRL	4.0	0.100	EPA 300.0	8/8/06	---
Mercury**	SA49098-01	BRL	0.002	0.00020	EPA 245.1	8/14/06	---
Selenium	SA49098-01	BRL	0.05	0.0005	EPA 200.8	8/8/06	---
Sodium	SA49098-01	9.27	none	0.500	EPA 200.7	8/11/06	---
Antimony	SA49098-01	BRL	0.006	0.0005	EPA 200.8	8/8/06	---
Beryllium	SA49098-01	BRL	0.004	0.0005	EPA 200.8	8/8/06	---
Nickel	SA49098-01	BRL	none	0.0010	EPA 200.8	8/8/06	---
Thallium	SA49098-01	BRL	0.002	0.0005	EPA 200.8	8/8/06	---
Cyanide	SA49098-01	BRL	0.2	0.0100	10-204-00-1-A	8/12/06	---
Compound (unregulated)	Lab Sample ID#	Result mg/L	MCL mg/L	Detection Limit mg/L	Analytical Method	Date Analyzed	Lab Symbol
Sulfate	SA49098-01	8.06	none	1.00	EPA 300.0	8/8/06	---

* There is also a secondary MCL for fluoride which is 2.0 mg/L
 ** Please note that if method 245.1 is used for mercury, only method revision 3.0 will be accepted by DEP.

Laboratory Director Signature and Date

Attention: Mail TWO copies of this report to your DEP Regional Office within 30 days of receipt of results and no later than 10 days after the end of the reporting period.
 FOR DEP/DWS USE ONLY: PLEASE INITIAL & DATE AS COMPLETED

Accepted:	Disapproved:	Data Entered into WQTS:
Comments:		